

ALTERNATING CURRENT GENERATOR UPDATED

SERIAL NO. 6310484 kVA 68000 RPM 400

P.F. 0.90 VOLTS 13800 kW 61200

AMP ARM. 2845 AMP FIELD 630 EXC. VOLTS 360

PHASE 3 FREQUENCY 60 POLES 18

kVA 68000 ARM. BY RTD 60°C

kVA 78200 ARM. BY RTD 80°C

RISE OVER 40°C AMBIENT

YEAR OF REWIND 2003

PLACER COUNTY WATER AGENCY
MIDDLE FORK AMERICAN RIVER PROJECT
FERC NO. 2079
MIDDLE FORK POWER HOUSE
GENERATOR UNIT NO. 2
NEW NAMEPLATE, 2003

Placer County Water Agency

Power System: 24625 Harrison St. • Mail: P.O. Box 667 • Foresthill, California 95631
(530) 367-2291 (530) 885-6917 FAX (530) 367-4440



ORIGINAL
A Public Agency

BOARD OF DIRECTORS
Pauline Rocucci • Alex Ferreira
Otis Wollan • Lowell Jarvis
Michael R. Lee
David A. Breninger, General Manager
Ed Tiedemann, General Counsel

October 27, 2004
2004 NOV -3 P 3:02
FILED
OFFICE OF THE
SECRETARY
FEDERAL ENERGY
REGULATORY COMMISSION

The Secretary
Attn: DHAC (Engineering Group, Billy Guey-lee)
Federal Energy Regulatory Commission
888 First Street
Washington, D.C. 20426

Re: FERC Project No. 2079-CA

Dear Mr. Guey-lee:

The purpose of this letter is to provide a photograph of the new nameplate to the Commission, as requested in the ORDER AMENDING LICENSE, REVISING ANNUAL CHARGES, AND APPROVING A REVISED EXHIBIT M, issued September 8, 2004. Middle Fork Powerhouse Unit No. 2 generator was rewound and the new winding is rated for a higher capacity than the old winding. The photograph is of the new nameplate listing the higher capacity. We have also enclosed a photograph of the old nameplate. We are also sending copies of the photographs to the Commission's San Francisco Regional Office.

If you have any questions, please contact me at (530) 885-6917 or sjones@pcwa.net.

Sincerely,

PLACER COUNTY WATER AGENCY

Stephen J. Jones
Power System Manager

Enclosure

cc: David Breninger
Takeshi Yamashita
Edward J. Tiedemann

ALTERNATING CURRENT GENERATOR

PHASE	3	NO.	16310484
K.V.A.	6100.0	TYPE, FORM	TAK-RCM
VOLTS	13800	EXCITER VOLTS	375
AMPS	2552	FIELD AMPS	595
POLES	18	ARM TEMP RISE	6.0°C
CYCLES	60	FIELD TEMP RISE	6.0°C
R.P.M.	400	AMBIENT TEMP	4.0°C
P.F.	0.9	ARM CONNECTION	Y
RATING	CONTINUOUS		
STANDARD SPECIFICATION			ASA-C50.1-1955
MANUFACTURED IN	1965		

Toshiba

TOKYO SHIBAURA ELECTRIC CO. LTD.

TOKYO JAPAN

PLACER COUNTY WATER AGENCY
 MIDDLE FORK AMERICAN RIVER PROJECT
 FERC NO. 2079
 MIDDLE FORK POWERHOUSE
 GENERATOR UNIT NO. 2
 ORIGINAL NAMEPLATE, 1966-2003

**ALTERNATING CURRENT GENERATOR
UPDATED**

SERIAL NO. 6310484 kVA 68000 RPM 400

P.F. 0.90 VOLTS 13800 kW 61200

AMP ARM. 2845 AMP FIELD 630 EXC. VOLTS 360

PHASE 3 FREQUENCY 60 POLES 18

kVA 68000 ARM. BY RTD 60°C

kVA 78200 ARM. BY RTD 80°C

RISE OVER 40°C AMBIENT

YEAR OF REWIND 2003

**PLACER COUNTY WATER AGENCY
MIDDLE FORK AMERICAN RIVER PROJECT
FERC NO. 2079
MIDDLE FORK POWER HOUSE
GENERATOR UNIT NO. 2
NEW NAMEPLATE, 2003**